



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
RENEWAL of NO OBJECTION CERTIFICATE**



| | | | | |
|-----------|--------------------------------|--------------|------------|--|
| Ack. No.: | 170600002018 | Issue Date : | 21/01/2019 | |
| NOC: | 0005950/RENEWAL/Hyderabad/2019 | | | |
| NOC TYPE: | RENEWAL* | | | |

| | |
|-------------|------------|
| Valid Upto: | 20-01-2024 |
|-------------|------------|

| | |
|--------------------|---|
| Applicant Details: | MONOHAR DONTULA,9000133274,D.No. 12-1-1325/16, 12-1-1325/16/A, Shanti Nagar, Lallagda, Secunderabad |
|--------------------|---|

| | |
|--------------------------------|--|
| Building for which NOC issued: | TAKSHASILA PUBLIC SCHOOL,D.no:12-1-1325/16, 12-1-1325/16/A, Shanti Nagar, Lallaguda, Secunderabad/-Lalpet/Secunderabad/Hyderabad |
|--------------------------------|--|

| | | | | |
|---|-----------------|-------------------|--|------------|
| Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening: | No | | | |
| Plot Area (Sq. Mtrs): | 3167.55 | Height (Metres): | 12.00 | |
| Open Spaces (Metres): | North: 3.73 | South: (F) 6.00 | East: 6.00 | West: 2.50 |
| No. of Floors: 0 Cellars, 0 Stilts, 1 Ground, 3 Floors, 0 Terrace | Occupancy Type: | | EDUCATIONAL B-1 Schools up to senior secondary level | |
| Total Built-up Area (Sq.Mtrs): | 3167.55 | Staircases: | No. of Staircases Required/Proposed: | 3 |
| Fees Paid (₹): | 37500 | | Aggregate Width Required/Proposed (Metres): | 3.90 |

Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

| | | | | | |
|--|----|---|-------|-----------------------------|---|
| Fire Extinguisher: | 18 | First Aid Hose Reel: | 8 | Wet Riser: | 0 |
| Down Comer: | 0 | Yard Hydrant: | 4 | Automatic Sprinkler System: | 0 |
| Manually Operated Electronic Fire Alarm Systems: | 0 | Terrace Tank (Litres): | 10000 | | |
| Automatic Detection and Alarm System: | 0 | Underground Static Water Storage Tank (Litres): | 50000 | | |

| | | | |
|--|-------------|-----------------|---------------------------------|
| Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level | Type | Quantity | (Capacity in Litres/min) |
| | Electrical | 0 | 0 |
| | Diesel | 0 | 0 |
| | Jockey | 0 | 0 |

| | |
|---|---------------------------------|
| Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2 | (Capacity in Litres/min) |
| | 900 |

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

* For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf*.